

BEER AND/OR LIQUOR RENEWAL CERTIFICATE OF INSPECTION

This application will be on the March 25, 2024 Council Agenda

Business Name Caseys #3319 Phone Number \_\_\_\_\_

Address 1800 S B Ave

Manager's Name \_\_\_\_\_ Phone Number \_\_\_\_\_

Address \_\_\_\_\_

Owners Name \_\_\_\_\_ Phone Number \_\_\_\_\_

Address \_\_\_\_\_

I hereby certify that the premises where the above applicant intends to operate pursuant to a beer or liquor license has been inspected by the undersigned and that on the date of the inspection the premises (conforms/did not conform) to all applicable fire regulations of the City of Nevada and the State of Iowa.

The Fire Department recommends  approval  denial of a beer or liquor license to this business.

3/11/24  
Date

[Signature]  
FIRE INSPECTOR AND/OR BUILDING INSPECTOR

COMMENTS/OR REASONS IF DENIED: (Write on back or another sheet if needed)

- ① mold ceiling tile is near vents - possible water leak
- ② illegal wire holding 2 - 20 Amp fuses together
- ③ EAST EXIT sign battery dead when tested
- ④ 3 foot clearance around elect panels
- ⑤ keep clear path of egress around west kitchen exit door.

\* shipped orders to casey's HQ to fix.

store - 3319 @ GGS retail.com

caroline Black @ Hotmart.com



# State of Iowa

## Alcoholic Beverages Division

### Applicant

NAME OF LEGAL ENTITY	NAME OF BUSINESS(DBA)	BUSINESS		
Casey's Marketing Company	Casey's General Store #3319	(515) 217-4643		
ADDRESS OF PREMISES	PREMISES SUITE/APT NUMBER	CITY	COUNTY	ZIP
1800 South B Ave		Nevada	Story	50201
MAILING ADDRESS	CITY	STATE	ZIP	
1 SE CONVENIENCE BLVD	Ankeny	Iowa	50021	

### Contact Person

NAME	PHONE	EMAIL
LICENSING DEPARTMENT	(515) 446-6179	licensingteam@caseys.com

### License Information

LICENSE NUMBER	LICENSE/PERMIT TYPE	TERM	STATUS
LE0002458	Class E Retail Alcohol License	12 Month	Submitted to Local Authority

TENTATIVE EFFECTIVE DATE	TENTATIVE EXPIRATION DATE	LAST DAY OF BUSINESS
Apr 30, 2024	Apr 29, 2025	

#### SUB-PERMITS

Class E Retail Alcohol License

#### PRIVILEGES



# State of Iowa

Alcoholic Beverages Division

## Status of Business

BUSINESS TYPE

Corporation

## Ownership

### • Individual Owners

NAME	CITY	STATE	ZIP	POSITION	% OF OWNERSHIP	U.S. CITIZEN
ERIC LARSEN	Ankeny	Iowa	50023	TREASURER	0.00	Yes
SCOTT FABER	Johnston	Iowa	50131	SECRETARY	0.00	Yes
SAMUEL JAMES	Ankeny	Iowa	50021	PRESIDENT	0.00	Yes
BRIAN JOHNSON	JOHNSTON	Iowa	50131	VICE PRESIDENT	0.00	Yes
DOUGLAS BEECH	ANKENY	Iowa	50021	ASSISTANT SECRETARY	0.00	Yes
42-0935283 Casey's General Stores, Inc.	Ankeny	Iowa	50021--804	Owner	100.00	Yes
CASEY'S GENERAL STORES	Urbandale	Iowa	50322			

## Insurance Company Information



# State of Iowa

Alcoholic Beverages Division

INSURANCE COMPANY

POLICY EFFECTIVE DATE

POLICY EXPIRATION DATE

DRAM CANCEL DATE

OUTDOOR SERVICE EFFECTIVE  
DATE

OUTDOOR SERVICE EXPIRATION  
DATE

BOND EFFECTIVE DATE

TEMP TRANSFER EFFECTIVE  
DATE

TEMP TRANSFER EXPIRATION  
DATE

## Ray Reynolds

---

**To:** store\_3319@cgsretail.com  
**Cc:** carolineblack@hotmail.com  
**Subject:** Caseys Inspection

Good afternoon,


I conducted the Caseys store inspection at 1800 S. B ave for the liquor license compliance to the fire code. Your license will be recommended approved. On 3-11-24 the following things were listed to be addressed:

- 1) On one of the electrical panels, there was a wire tied to two 20 amp breakers acting as a fusible link to the breakers. Wire attachments to circuit breakers do not meet the National Electrical Code NFPA 70. Have an electrician place a proper breaker in the panel and remove the wire tying to the two breakers together.
- 2) The exit sign above the East exit door did not operate correctly when the test button was pressed. This indicates the battery back up is either dead or not installed. Address this with a new battery in the sign.
- 3) Maintain 3 foot clearance around all electrical panels. There were signs to indicate this but it was not being followed. Consider painting the area yellow to visually deter employees from putting items in the space near panels.
- 4) The exit door in the kitchen was blocked with supplies. I realize I did the inspection on the same day you received a truck load of deliveries, so make every attempt after deliveries to move items to shelves or away from exits.
- 5) There were several ceiling tiles that appeared to be moldy. This indicates some presence of moisture or a leak in the ceiling. These items do not get better with time. It is important to address what is causing the leak to avoid the issue spreading to electrical services, lights, or other building components.

Let me know when the items are corrected or send a written plan of correction to me via email so we know the items were addressed and corrected. My email is [rreynolds@cityofnevadaaiowa.org](mailto:rreynolds@cityofnevadaaiowa.org)

Thank you for spending the time to walk through the inspection with me. Emergencies happen when we least expect it. Behing prepared and knowledgeable how to react is critical to keeping the emergency small.

Raymond A. Reynolds, M.A., CPM, CCP



Director of Fire & EMS/Police Officer  
City of Nevada  
1209 6<sup>th</sup> Street  
Nevada, Iowa 50201  
(515) 382-4593  
[rreynolds@cityofnevadaaiowa.org](mailto:rreynolds@cityofnevadaaiowa.org)