Item # 4D
Date: 11 24 25

Applicant

Name of Legal Entity: MI CASITA INC

Business Name (DBA): MI CASITA

Business Type: Corporation

Insurance Company: ILLINOIS CASUALTY CO

#### **Premises Address**

### **Mailing Address**

Street: 1115 6TH

ST

Street: 1115 6TH

ST

Suite/Apt:

City: NEVADA

City: NEVADA

Suite/Apt:

County: STORY

County: STORY

State: IOWA

State: IOWA

ZIP: 50201-18

27

ZIP: 50201-18

27

## **Application Information**

Application ID : 0-009-305-358

Application Type: Class "C" Retail Alcohol License (LC) Renewal

Current Stage: Local Authority Review

Premises Type: Restaurant

Term: 12 months

Effective Date: 15-Dec-2025

Expiration Date: 14-Dec-2026

| Inspection No:   | 25-236     |  |
|------------------|------------|--|
| Inspection Date: | 10/30/2025 |  |
| Inspection Time: | 0.33       |  |
| Inspected By:    |            |  |

# NEVADA PUBLIC SAFETY DEPARTMENT FIRE INSPECTION REPORT



|           |           | Inspection and Complianc | e Orders        | and the same and the same |       |
|-----------|-----------|--------------------------|-----------------|---------------------------|-------|
| Facility: | Mi-Casita | Address:                 | 1115 6th Street |                           |       |
| Phone:    |           | Address:                 |                 |                           |       |
| Fax:      |           | City:                    | City of Nevada  |                           |       |
| Email:    |           | State:                   | IA              | Postal Code:              | 50201 |
|           |           | Primary Contact          |                 |                           |       |
| Contact:  |           | Work:                    |                 |                           |       |
| Email:    |           | Cell:                    |                 |                           |       |

#### Inspection Type:

| Violation<br>Code | Days to<br>Correct* | Violation   | Notes | Location   |
|-------------------|---------------------|---|-------|--|
| 603.6             |                     | Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors. |       | In the patrol area<br>booth to provide<br>light to the kids<br>topping area. |

| Inspection Notes:           |    |  |
|-----------------------------|----|--|
| Inspector :<br>Ray Reynolds |    |  |
|                             | HR |  |

A variance procedure is available. Please contact the inspector named for further assistance with this or any other matter.

<sup>\*</sup> Number of days to correct from date inspected.