
April 27th / 2026

Water Pollution Control Council Report

- Regular operation, monitoring & maintenance of the wastewater treatment plant, lift stations, and remote flow basin.
- DNR Form 30 Part B special sampling analysis Final Samples collected.
- Installed new pH probes in Digester Units.
- Installed Final Clarifier Ladder.
- Enhanced Accessibility of Digester Unit.
- Working with DNR and PMMIC for decommissioning the Underground Storage Tank at the old facility.
 - System is now in Temporary Closure.
 - Completed UST Inspection with PMCCI and IDNR.
 - Looking into Decommission options & resources.
- Ongoing Punch list work being logged and completed at Phase 2.
- Ongoing Warranty Work Orders completed as assigned at Phase 3.
- Reviewing sewer samples to determine domestic strength in relation to Chloride and Sulfate.
- Staff serviced vehicles and mowers on site.
- Senior Operator progressed licensing to Grade 2 - Wastewater Treatment Operator